

WALLOPS WATER SYSTEM UPGRADES, IFB NNG14498523R

INDUSTRY QUESTIONS

13. Is there a requirement for Standby Temporary Pumps? The contract documents talk about a domestic and fire pump, so do we have to have backup pumps onsite as well?

NASA RESPONSE: The Sheet Notes on Sheet C-601 (Drawing number 16822) provide the pumping requirements. Those requirements instruct the contractor to maintain the existing full service currently provided by the domestic and fire pumps. The existing service has adequate redundancy.

14. On sheet M-105, would you please clarify if the pipe to and from existing pressure pumps 1 & 2 is to be replaced and if so, what size is it?

NASA RESPONSE: The pipe is to be replaced. Please refer to the response posted previously under question 7 for sizing information.

15. On sheet M-307, the section marked E, I can't find a corresponding section line on the plan view on sheet M-105. Would you please clarify where this section is to be taken?

NASA RESPONSE: Please refer to revised Sheet M-105 (Drawing number 16839) dated 6/12/14. This revision was incorporated in Amendment 1.

16. On sheet M-105, there are several lines that terminate at the matchline and do not have corresponding lines continuing from the other matchline. Would you please clarify?

NASA RESPONSE: Supplemental drawing record (drawing # 8879) is incorporated to show available detail. Amendment 2 incorporates this change to Section J.

17. On sheet M-105, the lines to and from the existing bypass pump do not include a diameter. Would you please clarify?

NASA RESPONSE: Supplemental drawing record drawing (drawing # 8879) is incorporated to show available detail. Amendment 2 incorporates this change to Section J.

18. Please confirm:

Bid Date- 6/19/14 at 2:30pm

Addendums-1

Bid Location- Goddard Space Flight Facility, Wallops Flight Facility
Visitors Reception Center (Bldg. N-1) Wallops Island, VA 23337

NASA RESPONSE: Please refer to Section 13 of the Standard Form 1442 and Section L.26 of the IFB. The number of addendums is now 2.

19. We plan on delivering a bid on Thursday for the referenced solicitation. What is required to gain access to the campus?

NASA RESPONSE: Special access is not required for entry to the bid receipt location, Wallops Flight Facility Visitors Reception Center, Building N-1. Building N-1 is open to the public.

20. Question No. 4 of the Industry Questions States that we must fill in Block 17 of the SF 1442 with the base bid options and the total bid amount. As there is not enough room in Block 17, can we just use the Bid Schedule (Exhibit 1 to Standard Form 1442) only?

NASA RESPONSE: Block 17 of the SF1442 has been amended. Amendment 2 incorporates this change.

21. Page 72 of the Solicitation gives the goals for Minority and Female Participation. Will we need to submit a Subcontracting Plan with the bid?

NASA RESPONSE: To comply with Executive Order 11246, contractors must demonstrate good faith efforts to meet their affirmative action goals for the employment of minorities and women in the construction industry. A "Notice of Requirement for Affirmative Action to Ensure Equal Employment Opportunity" is included in the bid specifications for all Federal and federally assisted construction contracts and subcontracts in excess of \$10,000. The Notice sets forth the goals for minority and female participation. The goals are expressed as a percentage of the hours worked by the contractor's aggregate work force in each trade on all construction work performed in the geographic area, regardless of whether the work is Federal, federally assisted or non-federal. A subcontracting plan is not required with the solicitation.

22. Do you have a list of bidders for the Water System Upgrade?

NASA RESPONSE: The list of mandatory site visit attendees is located on the FedBizOpps site.